

Hot Work Permit (UKI)

*All temporary operations involving open flames or producing heat and/or sparks require a Hot Work Permit. This includes, but is not limited to, Brazing, Cutting, Grinding, Soldering, Thawing, and Welding.

This permit is valid only while the listed precautions remain in place. It must be suspended or cancelled if conditions change or hazards increase.

Proposed Start & End Time:	
Date of Issue:	
Permit Valid Until:	
Contractor:	
Description of Work:	
Competent Person:	
Work Location:	

Type of Work Performed (select all that apply):

- ☐ Cutting
- ☐ Soldering / Grinding
- ☐ Oxy / Acetylene Torch
- ☐ Gas Welding
- ☐ Electric Arc Welding
- ☐ Acetylene / MAPP Gas

This Hot Work Permit is issued in accordance with the UK Regulatory Reform (Fire Safety) Order 2005 and CDM 2015 obligations where applicable.

Required Precautions (check all that apply):

General:

- ☐ Fire Risk Assessment reviewed prior to work
- ☐ Cutting and welding equipment in good condition
- ☐ Sprinkler system in service
- ☐ Fire-fighting equipment inspected and ready
- ☐ Requirements within 35 Feet of Work:
- ☐ Floors swept and clean of combustible material
- ☐ Combustible floors (e.g. wood, tile, carpet, etc.) wet down, covered with damp sand or fire blankets
- ☐ No flammable materials stored in area
- ☐ Wall and floor openings covered
- ☐ Walkways protected beneath hot work

Work on Wall or Ceiling:

- ☐ Combustibles removed from other side of wall
- ☐ Construction is non-combustible and without combustible covering or insulation

Disclaimer: This template is provided by HammerTech for general guidance only. Users are solely responsible for its correct use and compliance with applicable laws. HammerTech accepts no liability for its use.

Hot Work Permit (UKI)

*All temporary operations involving open flames or producing heat and/or sparks require a Hot Work Permit. This includes, but is not limited to, Brazing, Cutting, Grinding, Soldering, Thawing, and Welding.

This permit is valid only while the listed precautions remain in place. It must be suspended or cancelled if conditions change or hazards increase.

Work in Confined Space:

- ☐ Confined Space Permit
- ☐ Equipment cleaned of all liquid combustibles
- ☐ Containers purged of vapours

Fire Watch:

- ☐ Fire watch will be provided during and for 30 minutes after work (including breaks)
- ☐ Fire watch is supplied with and extinguisher and/or water pump can
- ☐ Fire watch is trained on use of equipment

Authorised Personnel:	
Role:	Name:
Fire Watch	
Welder	
Supervisor	
Other	

Signatures:	
Contractor Supervisor:	
Site Manager / Principal Contractor	
Fire Watch:	

Work Completion Review:

- ☐ Hot Work Completed – No incidents reported